

Bulletin | Danfoss TurboCor Compressors

Customer Notification

B-CN-033-EN Rev A

March 14, 2015

SUBJECT: New Front and Rear Bearing Feedthroughs

Purpose

This document is being sent as a notification of implementation to our customers concerning a new design revision for the Front and Rear bearing feedthroughs. This change affects all TT and TG series compressors.

Summary

Background

Danfoss TurboCor is sourcing a new

This is only relevant to new compressors and does not apply to refurbished compressors. Additionally, the type of sealant used on all threaded external ports is being changed. The current sealant, Loctite 554 is being replaced with a soft set thread sealant called Megaloc.

Action Required

No Action is required by customers at this time.

For any additional information regarding this change, please contact your Key Account Manager.